CERTIFICATE OF CONFORMITY

Intertek SAI Global hereby grants:

Zurn Wilkins
Zurn Industries, LLC

1747 Commerce Way, Paso Robles, CA United States

Watermark Certificate of Conformity

Evaluated to:
AS/NZS 2845.1:2022 - Water supply - Backflow prevention devices - Materials, design and performance requirements

"the WaterMark Licensee" the right to use or arrange the use of the WaterMark as shown below only in respect of the goods described and detailed on the product schedule identified on www.register.saiglobal.com which are produced by the WaterMark Licensee or on behalf of the WaterMark Licensee* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the WaterMark^ and the Terms and Conditions for certification. The WaterMark Licensee covenants to comply with all the Rules and Terms and Conditions.

This Certificate is issued by a JAS-ANZ accredited certification body. The Scheme Owner, Administering Body and Accreditation Body do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The Scheme Owner disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate

^ Only product that has been listed in the schedule of this certificate as compliant with the Lead Free provisions of the National Construction Code Volume 3 - may use the Lead Free Watermark.

Certificate No:
WMKA1379

Originally Certified:
17 July 1996

Current Certification:
8 October 2026

Issued:
8 October 2026

Expires:
16 July 2031

Mark Thomas
Executive Vice President
Assurance, Sustainability, AgriWorld & Food

SAI Global Certification Services Pty Ltd
Level 7 Suite 7.01 45 Clarence Street
Sydney NSW 2000 Australia

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Intertek SAI Global hereby grants:

Zurn Wilkins
Zurn Industries, LLC

1747 Commerce Way, Paso Robles, CA United States

Evaluated to:
AS/NZS 2845.1:2022 - Water supply - Backflow prevention devices - Materials, design and performance requirements

Model identification of the goods on which the WATERMARK may be used:

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
100-310SPD	310	ZURN WILKINS	SINGLE CHECK VALVE TESTABLE	Yes	SCVT	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	DUCTILE IRON	29 Aug 2025
100-310SPE	310	ZURN WILKINS	SINGLE CHECK VALVE TESTABLE	Yes	SCVT	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
1006338	310	ZURN WILKINS	4-310BS (100-310TCV) Wilkins Scv Testable 100mm T/E	Yes	SCVT	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
1006339	310	ZURN WILKINS	6-310BS (150-310ALTCV) Wilkins Scv Testable 150mm T/E	Yes	SCVT	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
1013613	310	ZURN WILKINS	6-310BSG (150-310ALTCV) Wilkins Scv Testable 150mm R/G	Yes	SCVT	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
150-310SPD	310	ZURN WILKINS	SINGLE CHECK VALVE TESTABLE	Yes	SCVT	DN150 (6")	1200 kPa	60C	DN150/D x DN150/D	DUCTILE IRON	29 Aug 2025
150-310SPE	310	ZURN WILKINS	SINGLE CHECK VALVE TESTABLE	Yes	SCVT	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
200-310ALTCV	310	ZURN WILKINS	8-310BSG (200-310ALTCV) 200MM SCV TESTABLE ROLL GROOVED VALVE ONLY	Yes	SCVT	DN200 (8")	1200 kPa	60C	DN200/GROOVE x DN200/GROOVE	DUCTILE IRON	29 Aug 2025
2120687	310	ZURN WILKINS	4-310BSG (100-310ALTCV) Wilkins Scv Testable 100mm R/G	Yes	SCVT	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
2120737	310	ZURN WILKINS	4-310BSD (100-310DALDT) Wilkins Scv Testable 100mm T/D	Yes	SCVT	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	DUCTILE IRON	29 Aug 2025
4000081	310	ZURN WILKINS	8-310BS (200-310TCV) Wilkins Scv Testable 200mm T/E	Yes	SCVT	DN200 (8")	1200 kPa	60C	DN200/E x DN200/E	DUCTILE IRON	29 Aug 2025
1000611	310DA	ZURN	SE100-	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/E x	DUCTILE	29 Aug

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
		WILKINS	310DAL25T(FL) Sdcv 25mm Test Sew Spacer Byp 100mm T/E						DN100/E	IRON	2025
1000612	310DA	ZURN WILKINS	SE100-310DAL25T(RG) Sdcv 25mm Test Sew Spacer Byp 100mm R/G	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
1000613	310DA	ZURN WILKINS	SE150-310DAL25T(FL) Sdcv 25mm Test Sew Spacer Byp 150mm T/E	Yes	SCDAT	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
1000614	310DA	ZURN WILKINS	SE150-310DAL25T(RG) Sdcv 25mm Test Sew Spacer Byp 150mm R/G	Yes	SCDAT	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
1023607	350	ZURN WILKINS	212-350LBSE (65-350L) Wilkins DCV Valve Only Table E 65mm	Yes	DCV	DN65 (2-1/2")	1200 kPa	60C	DN65/E x DN65/E	DUCTILE IRON	29 Aug 2025
1023608	350	ZURN WILKINS	3-350LBSE (80-350L) Wilkins DCV Valve Only Table E 80mm	Yes	DCV	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	DUCTILE IRON	29 Aug 2025
1023609	350	ZURN WILKINS	4-350LBSE (100-350L) Wilkins DCV Valve Only Table E 100mm	Yes	DCV	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
1023610	350	ZURN WILKINS	6-350LBSE (150-350L) Wilkins DCV Valve Only Table E 150mm	Yes	DCV	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
1023611	350	ZURN WILKINS	8-350LBSE (200-350L) Wilkins DCV Valve Only Table E 200mm	Yes	DCV	DN200 (8")	1200 kPa	60C	DN200/E x DN200/E	DUCTILE IRON	29 Aug 2025
1023612	350	ZURN WILKINS	10-350LBSE (250-350L) Wilkins DCV Valve Only Table E 250mm	Yes	DCV	DN250 (10")	1200 kPa	60C	DN250/E x DN250/E	DUCTILE IRON	29 Aug 2025
4000017	350	ZURN WILKINS	4-350ALBS (100-350AL) Wilkins DCV Valve Only RG 100mm	Yes	DCV	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
4000049	350	ZURN WILKINS	6-350ALBS (150-350AL) Wilkins DCV Valve Only RG 150mm	Yes	DCV	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
4000082	350	ZURN WILKINS	8-350ALBS (200-350AL) Wilkins DCV Valve Only RG 200mm	Yes	DCV	DN200 (8")	1200 kPa	60C	DN200/GROOVE x DN200/GROOVE	DUCTILE IRON	29 Aug 2025
4000102	350	ZURN WILKINS	34-350LFTBT (20-350LT) Wilkins Double Check Valve WM 20mm	Yes	DCV	GB3/4"	1200 kPa	82C	GB3/4 X GB3/4	COPPER ALLOY / PLASTIC	29 Aug 2025
4000121	350	ZURN WILKINS	1-350LFTBT (25-350LT) Wilkins Double Check Valve WM 25mm	Yes	DCV	GB1"	1200 kPa	82C	GB1 X GB1	COPPER ALLOY / PLASTIC	29 Aug 2025
4000148	350	ZURN WILKINS	114-350LFTBT (32-350LT) Wilkins Double Check Valve WM 32mm	Yes	DCV	GB1-1/4"	1200 kPa	82C	GB1-1/4 X GB1-1/4	COPPER ALLOY / PLASTIC	29 Aug 2025
4000154	350	ZURN WILKINS	112-350LFTBT (40-350LT) Wilkins Double Check Valve WM	Yes	DCV	GB1-1/2"	1200 kPa	82C	GB1-1/2 X GB1-1/2	COPPER ALLOY / PLASTIC	29 Aug 2025

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
			40mm								
4000160	350	ZURN WILKINS	2-350LFTBT (50-350LT) Wilkins Double Check Valve WM 50mm	Yes	DCV	GB2"	1200 kPa	82C	GB2 X GB2	COPPER ALLOY / PLASTIC	29 Aug 2025
250-350DA20SYD	350DA	ZURN WILKINS	250MM DDCV TESTABLE ROLL GROOVED WITH 20MM METER BYPASS	Yes	DCDA	DN250 (10")	1200 kPa	60C	DN250/E x DN250/E	DUCTILE IRON	29 Aug 2025
4000180	350DA	ZURN WILKINS	80-350DA20SYD Wilkins 80mm T/E Ddcv W/ 20mm BP	Yes	DCDA	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	DUCTILE IRON	29 Aug 2025
1000626	310DA	ZURN WILKINS	YVW100-310DAL25T(FL) Sdcv 25mm Test Yvw Meter Byp 100mm T/E	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
1000627	310DA	ZURN WILKINS	YVW100-310DAL25T(RG) Sdcv 25mm Test Yvw Meter Byp 100mm R/G	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
1000628	310DA	ZURN WILKINS	YVW150-310DAL25T(FL) Sdcv 25mm Test Yvw Meter Byp 150mm T/E	Yes	SCDAT	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
1000629	310DA	ZURN WILKINS	YVW150-310DAL25T(RG) Sdcv 25mm Test Yvw Meter Byp 150mm R/G	Yes	SCDAT	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
100-310DAL20DT	310DA	ZURN WILKINS	100MM SDCV TESTABLE TABLE D WITH 20MM METER BYPASS	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	DUCTILE IRON	29 Aug 2025
100-310DAL20SP	310DA	ZURN WILKINS	100MM SDCV TESTABLE TABLE E WITH 20MM SPACER BYPASS	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
180437	350DA	ZURN WILKINS	100-350DA20SYD Wilkins 100mm T/E Ddcv W/ 20mm BP	Yes	DCDA	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
4000018	350DA	ZURN WILKINS	100-350DA20SYDRG Wilkins 100mm R/G Ddcv W/ 20mm BP	Yes	DCDA	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
4000019	350DA	ZURN WILKINS	100-350DA20SYDRG-S Wilkins 100mm R/G Ddcv W/ 20mm BP Spacer	Yes	DCDA	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
4000020	350DA	ZURN WILKINS	150-350DA20SYD-S Wilkins 100mm T/E Ddcv W/ 20mm BP Spacer	Yes	DCDA	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
4000050	350DA	ZURN WILKINS	150-350DA20RG-S Wilkins 150mm R/G Ddcv W/ 20mm BP Spacer	Yes	DCDA	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
4000051	350DA	ZURN WILKINS	150-350DA20-S Wilkins 150mm T/E Ddcv W/ 20mm BP Spacer	Yes	DCDA	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
4000052	350DA	ZURN WILKINS	150-350DA20SYD	Yes	DCDA	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
			Wilkins 150mm T/E Ddcv W/ 20mm BP								
4000053	350DA	ZURN WILKINS	150-350DA20SYD Wilkins 150mm R/G Ddcv W/ 20mm BP	Yes	DCDA	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
4000083	350DA	ZURN WILKINS	200-350DA20SYD Wilkins 200mm T/E Ddcv W/ 20mm BP	Yes	DCDA	DN200 (8")	1200 kPa	60C	DN200/E x DN200/E	DUCTILE IRON	29 Aug 2025
4000084	350DA	ZURN WILKINS	200-350DA25SYD Wilkins 200mm T/E Ddcv W/ 25mm BP	Yes	DCDA	DN200 (8")	1200 kPa	60C	DN200/E x DN200/E	DUCTILE IRON	29 Aug 2025
4000164	350DA	ZURN WILKINS	65-350DA20SYD Wilkins 65mm T/E Ddcv W/ 20mm BP	Yes	DCDA	DN65 (2-1/2")	1200 kPa	60C	DN65/E x DN65/E	DUCTILE IRON	29 Aug 2025
1001689	375	ZURN WILKINS	112-375LFTBT (40-375LT) Wilkins Backflow Rpz Device Only 40mm	Yes	RPZD	GB1-1/2"	1200 kPa	82C	GB1-1/2 X GB1-1/2	COPPER ALLOY / PLASTIC	29 Aug 2025
1001690	375	ZURN WILKINS	2-375LFTBT (50-375LT) Wilkins Backflow Rpz Device Only 50mm	Yes	RPZD	GB2"	1200 kPa	82C	GB2 X GB2	COPPER ALLOY / PLASTIC	29 Aug 2025
1023602	375	ZURN WILKINS	212-375LBSE (65-375L) Wilkins Backflow Rpz Device Only 50mm	Yes	RPZD	DN65 (2-1/2")	1200 kPa	60C	DN65/E x DN65/E	DUCTILE IRON	29 Aug 2025
1023603	375	ZURN WILKINS	3-375LBSE (80-375L) Wilkins Rpz Valve Only Table E 80mm	Yes	RPZD	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	DUCTILE IRON	29 Aug 2025
1023604	375	ZURN WILKINS	4-375LBSE (100-375L) Wilkins Rpz Valve Only Table E 100mm	Yes	RPZD	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
1023605	375	ZURN WILKINS	6-375LBSE (150-375L) Wilkins Rpz Valve Only Table E 150mm	Yes	RPZD	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	DUCTILE IRON	29 Aug 2025
1023606	375	ZURN WILKINS	8-375LBSE (200-375L) Wilkins Rpz Valve Only Table E 200mm	Yes	RPZD	DN200 (8")	1200 kPa	60C	DN200/E x DN200/E	DUCTILE IRON	29 Aug 2025
150-375AL	375	ZURN WILKINS	6-375ALBS (150-375AL) WILKINS 150MM 375 RPZD ROLL GROOVE VALVE ONLY	Yes	RPZD	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
4000030	375	ZURN WILKINS	4-375ALBS (100-375AL) Wilkins Rpz Valve Only 100mm RG	Yes	RPZD	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
4000105	375	ZURN WILKINS	34-375LFTBT (20-375LT) Wilkins Backflow Rpz Device Only 20mm	Yes	RPZD	GB3/4"	1200 kPa	82C	GB3/4 X GB3/4	COPPER ALLOY / PLASTIC	29 Aug 2025
4000110	375	ZURN WILKINS	10-375LBSE (250-375L) Wilkins Rpz Valve Only Table E 250mm	Yes	RPZD	DN250 (10")	1200 kPa	60C	DN250/E x DN250/E	DUCTILE IRON	29 Aug 2025
4000124	375	ZURN	1-375LFTBT (25-	Yes	RPZD	GB1"	1200 kPa	82C	GB1 X GB1	COPPER	29 Aug

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
		WILKINS	375LT) Wilkins Backflow Rpz Device Only 25mm							ALLOY / PLASTIC	2025
4000151	375	ZURN WILKINS	114-375LFTBT (32-375LT) Wilkins Backflow Rpz Device Only 32mm	Yes	RPZD	GB1-1/4"	1200 kPa	82C	GB1-1/4 X GB1-1/4	COPPER ALLOY / PLASTIC	29 Aug 2025
100-475L	475	ZURN WILKINS	4-475LBS 100MM WILKINS RPZD "N" PATTERN VALVE ONLY	Yes	RPZD	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100/GROOVE	DUCTILE IRON	29 Aug 2025
150-475L	475	ZURN WILKINS	6-475LBS 150MM WILKINS RPZD "N" PATTERN VALVE ONLY	Yes	RPZD	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
200-475L	475	ZURN WILKINS	8-475LBS 200MM WILKINS RPZD "N" PATTERN VALVE ONLY	Yes	RPZD	DN200 (8")	1200 kPa	60C	DN200/GROOVE x DN200/GROOVE	DUCTILE IRON	29 Aug 2025
1006726	700	ZURN WILKINS	32-700DC Wilkins Dual Check Valve Fxf 32mm (114UFX114F-700FPBS)	No	DCV	G1-1/4"	1200 kPa	82C	G1-1/4 x G1-1/4	COPPER ALLOY	10 Dec 2024
1006728	700	ZURN WILKINS	40-700DC Wilkins Dual Check Valve Fxf 40mm (112UFX112F-700FPBS)	No	DCV	G1-1/2"	1200 kPa	82C	G1-1/2 x G1-1/2	COPPER ALLOY	10 Dec 2024
1011082	700	ZURN WILKINS	15-700DC Wilkins Dual Check Valve Fxf 15mm	No	DCV	G1/2"	1200 kPa	82C	G1/2 x G1/2	COPPER ALLOY	10 Dec 2024
1011270	700	ZURN WILKINS	20-700DC Wilkins Dual Check Valve Fxf 20mm	No	DCV	G3/4"	1200 kPa	82C	G3/4 x G3/4	COPPER ALLOY	10 Dec 2024
1011271	700	ZURN WILKINS	25-700DC Wilkins Dual Check Valve Fxf 25mm	No	DCV	G1"	1200 kPa	82C	G1 x G1	COPPER ALLOY	10 Dec 2024
020-705	705	ZURN WILKINS	DCV (34UFX34F-705BS)	Yes	DCV	G3/4"	1200 kPa	82C	G3/4 x G3/4	PLASTIC	29 Aug 2025
025-705	705	ZURN WILKINS	DCV (1UFX1F-705BS)	Yes	DCV	G1"	1200 kPa	82C	G1 x G1	PLASTIC	29 Aug 2025
1006738	760	ZURN WILKINS	12-760DRBS (15-760VDC) Wilkins Vented Dual Check Valve WM 15mm	No	DCAP	G1/2"	1200 kPa	82C	G1/2 x G1/2	COPPER ALLOY	10 Dec 2024
1006739	760	ZURN WILKINS	34-760DRBS (20-760VDC) Wilkins Vented Dual Check Valve WM 20mm	No	DCAP	G3/4"	1200 kPa	82C	G3/4 x G3/4	COPPER ALLOY	10 Dec 2024
100-310DAL20T/E	310DA	ZURN WILKINS	100MM SDCV TESTABLE TABLE E WITH 20MM METER BYPASS	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	DUCTILE IRON	29 Aug 2025
100-310DAL25DT	310DA	ZURN WILKINS	100MM SDCV TESTABLE TABLE D WITH 25MM METER BYPASS	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	DUCTILE IRON	29 Aug 2025
100-310DAL32DT	310DA	ZURN WILKINS	100MM SDCV TESTABLE TABLE D WITH 32MM METER BYPASS	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	DUCTILE IRON	29 Aug 2025
2109996	310DA	ZURN	BW100-	Yes	SCDAT	DN100 (4")	1200 kPa	60C	DN100/GROOVE	DUCTILE	29 Aug

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
		WILKINS	310DALRG Barwon Water Det Check Valve 100 X 40mm R/G						x DN100/GROOVE	IRON	2025
2109997	310DA	ZURN WILKINS	BW150-310DALRG Barwon Water Det Check Valve 150 X 40mm R/G	Yes	SCDAT	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150/GROOVE	DUCTILE IRON	29 Aug 2025
114-950LXLFTBT	950XL	ZURN WILKINS	32MM WILKINS 950 DCV VALVE ONLY TAPERED THREADS	No	DCV	GB1-1/4"	1200 kPa	82C	GB1-1/4 x GB1-1/4	COPPER ALLOY	10 Dec 2024
1-950LXLFTBT	950XL	ZURN WILKINS	25MM WILKINS 950 DCV VALVE ONLY TAPERED THREADS	No	DCV	GB1"	1200 kPa	82C	GB1 x GB1	COPPER ALLOY	10 Dec 2024
2-950LXLFTBT	950XL	ZURN WILKINS	50MM WILKINS 950 DCV ONLY TAPERED THREADS	No	DCV	GB2"	1200 kPa	82C	GB2 x GB2	COPPER ALLOY	10 Dec 2024
34-950LXLFTBT	950XL	ZURN WILKINS	20MM WILKINS 950 DCV VALVE ONLY TAPERED THREADS	No	DCV	GB3/4"	1200 kPa	82C	GB3/4 x GB3/4	COPPER ALLOY	10 Dec 2024
4000421	310DA	ZURN WILKINS	SE80-310DAL25T(FL) Sdcv 25mm Test Sew Spacer Byp 80mm FL	Yes	SCDAT	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	DUCTILE IRON	29 Aug 2025
4000446	310DA	ZURN WILKINS	YVW80-310DAL25T(FL) Sdcv 25mm Test Yvw Spacer Byp 80mm FL	Yes	SCDAT	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	DUCTILE IRON	29 Aug 2025
80-31020DAL	310DA	ZURN WILKINS	80MM SDCV TESTABLE TABLE E WITH 20MM METER BYPASS	Yes	SCDAT	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	DUCTILE IRON	29 Aug 2025
112-975LXLFTBT	975XL	ZURN WILKINS	40MM WILKINS 975 RPZ VALVE ONLY TAPERED THREADS	No	RPZD	GB1-1/2"	1200 kPa	82C	GB1-1/2 X GB1-1/2	COPPER ALLOY	10 Dec 2024
114-975LXLFTBT	975XL	ZURN WILKINS	32MM WILKINS 975 RPZ VALVE ONLY TAPERED THREADS	No	RPZD	GB1-1/4"	1200 kPa	82C	GB1-1/4 X GB1-1/4	COPPER ALLOY	10 Dec 2024
1-975LXLFTBT	975XL	ZURN WILKINS	25MM WILKINS 975 RPZ VALVE ONLY TAPERED THREADS	No	RPZD	GB1"	1200 kPa	82C	GB1 X GB1	COPPER ALLOY	10 Dec 2024
2-975LXLFTBT	975XL	ZURN WILKINS	50MM WILKINS 975 RPZ VALVE ONLY TAPERED THREADS	No	RPZD	GB2"	1200 kPa	82C	GB2 X GB2	COPPER ALLOY	10 Dec 2024
34-975LXLFTBT	975XL	ZURN WILKINS	20MM WILKINS 975 RPZ VALVE ONLY TAPERED THREADS	No	RPZD	GB3/4"	1200 kPa	82C	GB3/4 X GB3/4	COPPER ALLOY	10 Dec 2024
4000080	975XL	ZURN WILKINS	12-975LXLFTBS (15-975LT) Wilkins 975 Backflow Rpz Device Only 15mm	Yes	RPZD	GB1/2"	1200 kPa	82C	GB1/2 x GB1/2	COPPER ALLOY	29 Aug 2025
1023614	350	ZURN WILKINS	4-350LBSD (100-350LD) Wilkins DCV Valve Only Table D 100mm	Yes	No DCV	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	DUCTILE IRON	29 Aug 2025
10-350ASTLBS	350	ZURN WILKINS	10-350ASTLBS 250MM WILKINS DCV VALVE ONLY ROLL	Yes	DCV	DN250 (10")	1200 kPa	60C	DN250/GROOVE x DN250GROOVE	STAINLESS STEEL	29 Aug 2025

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
			GROOVE								
10-375ASTLBS	375	ZURN WILKINS	10-375ASTLBS 250MM WILKINS RPZD VALVE ONLY ROLL GROOVE	Yes	RPZD	DN250 (10")	1200 kPa	60C	DN250/GROOVE x DN250GROOVE	STAINLESS STEEL	29 Aug 2025
1060080	350	ZURN WILKINS	80-350SPE Wilkins DCV Only S/S 80mm T/E	Yes	DCV	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	STAINLESS STEEL	29 Aug 2025
1060081	350	ZURN WILKINS	100-350SPE Wilkins DCV Only S/S 100mm T/E	Yes	DCV	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	STAINLESS STEEL	29 Aug 2025
1060082	350	ZURN WILKINS	150-350SPE Wilkins DCV Only S/S 150mm T/E	Yes	DCV	DN150 (6")	1200 kPa	60C	DN100/E x DN100/E	STAINLESS STEEL	29 Aug 2025
1060091	350	ZURN WILKINS	100-350SPD Wilkins DCV Only S/S 100mm T/D	Yes	DCV	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	STAINLESS STEEL	29 Aug 2025
1060094	350	ZURN WILKINS	150-350SPD Wilkins DCV Only S/S 150mm T/D	Yes	DCV	DN150 (6")	1200 kPa	60C	DN100/D x DN100/D	STAINLESS STEEL	29 Aug 2025
1060097	375	ZURN WILKINS	65-375SPE Wilkins Rpz Only S/S 65mm	Yes	RPZD	DN65 (2-1/2")	1200 kPa	60C	DN65/E x DN65/E	STAINLESS STEEL	29 Aug 2025
1060098	375	ZURN WILKINS	80-375SPE Wilkins Rpz Only S/S 80mm	Yes	RPZD	DN80 (3")	1200 kPa	60C	DN80/E x DN80/E	STAINLESS STEEL	29 Aug 2025
1060099	375	ZURN WILKINS	100-375SPE Wilkins Rpz Only S/S 100mm T/E	Yes	RPZD	DN100 (4")	1200 kPa	60C	DN100/E x DN100/E	STAINLESS STEEL	29 Aug 2025
1060100	375	ZURN WILKINS	150-375SPE Wilkins Rpz Only S/S 150mm T/E	Yes	RPZD	DN150 (6")	1200 kPa	60C	DN150/E x DN150/E	STAINLESS STEEL	29 Aug 2025
1060110	375	ZURN WILKINS	100-375SPD Wilkins Rpz Only S/S 100mm T/D	Yes	RPZD	DN100 (4")	1200 kPa	60C	DN100/D x DN100/D	STAINLESS STEEL	29 Aug 2025
1060112	375	ZURN WILKINS	150-375SPD Wilkins Rpz Only S/S 150mm T/D	Yes	RPZD	DN150 (6")	1200 kPa	60C	DN150/D x DN150/D	STAINLESS STEEL	29 Aug 2025
112-950LXLTFTBT	950XL	ZURN WILKINS	40MM WILKINS 950 DCV VALVE ONLY TAPERED THREADS TOP ACCESS	No	DCV	GB1-1/2"	1200 kPa	82C	GB1-1/2 x GB1-1/2	COPPER ALLOY	10 Dec 2024
114-950LXLTFTBT	950XL	ZURN WILKINS	32MM WILKINS 950 DCV VALVE ONLY TAPERED THREADS TOP ACCESS	No	DCV	GB1-1/4"	1200 kPa	82C	GB1-1/4 x GB1-1/4	COPPER ALLOY	10 Dec 2024
1-950LXLTFTBT	950XL	ZURN WILKINS	25MM WILKINS 950 DCV VALVE ONLY TAPERED THREADS TOP ACCESS	No	DCV	GB1"	1200 kPa	82C	GB1 x GB1	COPPER ALLOY	10 Dec 2024
212-350ASTLBS	350	ZURN WILKINS	212-350ASTLBS 65MM WILKINS DCV VALVE ONLY ROLL GROOVE	Yes	DCV	DN65 (2-1/2")	1200 kPa	60C	DN65/GROOVE x DN65GROOVE	STAINLESS STEEL	29 Aug 2025
212-375ASTLBS	375	ZURN WILKINS	212-375ASTLBS 65MM WILKINS RPZD VALVE ONLY ROLL GROOVE	Yes	RPZD	DN65 (2-1/2")	1200 kPa	60C	DN65/GROOVE x DN65GROOVE	STAINLESS STEEL	29 Aug 2025
2-950LXLTFTBT	950XL	ZURN WILKINS	50MM WILKINS 950 DCV ONLY TAPERED THREADS TOP ACCESS	No	DCV	GB2"	1200 kPa	82C	GB2 x GB2	COPPER ALLOY	10 Dec 2024
34-950LXLTFTBT	950XL	ZURN WILKINS	20MM WILKINS 950 DCV VALVE	No	DCV	GB3/4"	1200 kPa	82C	GB3/4 x GB3/4	COPPER ALLOY	10 Dec 2024

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
			ONLY TAPERED THREADS TOP ACCESS								
4000060	375	ZURN WILKINS	6-375ASTLBS 150MM WILKINS RPZD VALVE ONLY ROLL GROOVE	Yes	RPZD	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150GROOVE	STAINLESS STEEL	29 Aug 2025
4000169	350	ZURN WILKINS	65-350SPE Wilkins DCV Only S/S 65mm T/E	Yes	DCV	DN65 (2-1/2")	1200 kPa	60C	DN65/E x DN65/E	STAINLESS STEEL	29 Aug 2025
4000818	350	ZURN WILKINS	8-350ASTLBS 200MM WILKINS DCV VALVE ONLY ROLL GROOVE	Yes	DCV	DN200 (8")	1200 kPa	60C	DN200/GROOVE x DN200GROOVE	STAINLESS STEEL	29 Aug 2025
4000819	375	ZURN WILKINS	8-375ASTLBS 200MM WILKINS RPZD VALVE ONLY ROLL GROOVE	Yes	RPZD	DN200 (8")	1200 kPa	60C	DN200/GROOVE x DN200GROOVE	STAINLESS STEEL	29 Aug 2025
4000859	375	ZURN WILKINS	3-375ASTLBS 80MM WILKINS RPZD VALVE ONLY ROLL GROOVE	Yes	RPZD	DN80 (3")	1200 kPa	60C	DN80/GROOVE x DN80GROOVE	STAINLESS STEEL	29 Aug 2025
4001045	350	ZURN WILKINS	4-350ASTLBS 100MM WILKINS DCV VALVE ONLY ROLL GROOVE	Yes	DCV	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100GROOVE	STAINLESS STEEL	29 Aug 2025
4001049	375	ZURN WILKINS	4-375ASTLBS 100MM WILKINS RPZD VALVE ONLY ROLL GROOVE	Yes	RPZD	DN100 (4")	1200 kPa	60C	DN100/GROOVE x DN100GROOVE	STAINLESS STEEL	29 Aug 2025
4001062	350	ZURN WILKINS	6-350ASTLBS 150MM WILKINS DCV VALVE ONLY ROLL GROOVE	Yes	DCV	DN150 (6")	1200 kPa	60C	DN150/GROOVE x DN150GROOVE	STAINLESS STEEL	29 Aug 2025
4001469	350	ZURN WILKINS	3-350ASTLBS 80MM WILKINS DCV VALVE ONLY ROLL GROOVE	Yes	DCV	DN80 (3")	1200 kPa	60C	DN80/GROOVE x DN80GROOVE	STAINLESS STEEL	29 Aug 2025
10000	700XL	ZURN WILKINS	15-700XL Wilkins Dual Check Valve Fxf 15mm	Yes	DCV	DN15 (1/2")	1200 kPa	82°C	Rp1/2 x Rp1/2	COPPER ALLOY	29 Aug 2025
10001	700XL	ZURN WILKINS	20-700XL Wilkins Dual Check Valve Fxf 20mm	Yes	DCV	DN20 (3/4")	1200 kPa	82°C	Rp3/4 x Rp3/4	COPPER ALLOY	29 Aug 2025
10002	700XL	ZURN WILKINS	25-700XL Wilkins Dual Check Valve Fxf 25mm	Yes	DCV	DN25 (1")	1200 kPa	82°C	Rp1 x Rp1	COPPER ALLOY	29 Aug 2025
10003	700XL	ZURN WILKINS	40-700XLFPBS Wilkins Dual Check Valve FxF 40mm	Yes	DCV	DN40 (1-1/2")	1200 kPa	82°C	Rp1-1/2 x Rp1-1/2	COPPER ALLOY	29 Aug 2025
10004	700XL	ZURN WILKINS	32-700XLFPBS Wilkins Dual Check Valve FxF 32mm	Yes	DCV	DN32 (1-1/4")	1200 kPa	82°C	Rp1-1/4 x Rp1-1/4	COPPER ALLOY	29 Aug 2025
180476	375	ZURN WILKINS	12-375LFTBT (15-375LT) Wilkins Backflow Rpz Device Only 15mm	Yes	RPZD	DN15 (R1/2")	1200 kPa	82°C	R1/2 X R1/2	COPPER ALLOY / PLASTIC	29 Aug 2025
112-950XL3LFTBT	950XL3	ZURN WILKINS	112-950XL3LFTBT WILKINS BACKFLOW DCV DEVICE ONLY 40MM	Yes	DCV	DN40 (1-1/2")	1200 kPa	82°C	R1-1/2 X R1-1/2	COPPER ALLOY	29 Aug 2025

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.

SCHEDULE TO
CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Brand Name	Product Description	Lead Free Compliant	Product Type	Nominal Size	Pressure Classification	Temperature Classification	Inlet/Outlet Designation	Material Designation	Date Endorsed
112-975XL3LFTBT	975XL3	ZURN WILKINS	112-975XL3LFTBT WILKINS BACKFLOW RPZ DEVICE ONLY 40MM	Yes	RPZD	DN40 (1-1/2")	1200 kPa	82°C	R1-1/2 X R1-1/2	COPPER ALLOY	29 Aug 2025
114-950XL3LFTBT	950XL3	ZURN WILKINS	114-950XL3LFTBT WILKINS BACKFLOW DCV DEVICE ONLY 32MM	Yes	DCV	DN32 (1-1/4")	1200 kPa	82°C	R1-1/4 X R1-1/4	COPPER ALLOY	29 Aug 2025
114-975XL3LFTBT	975XL3	ZURN WILKINS	114-975XL3LFTBT WILKINS BACKFLOW RPZ DEVICE ONLY 32MM	Yes	RPZD	DN32 (1-1/4")	1200 kPa	82°C	R1-1/4 X R1-1/4	COPPER ALLOY	29 Aug 2025
12-975XL3LFTBT	975XL3	ZURN WILKINS	12-975XL3LFTBT WILKINS BACKFLOW RPZ DEVICE ONLY 15MM	Yes	RPZD	DN15 (1/2")	1200 kPa	82°C	R1/2 X R1/2	COPPER ALLOY	29 Aug 2025
1-950XL3LFTBT	950XL3	ZURN WILKINS	1-950XL3LFTBT WILKINS BACKFLOW DCV DEVICE ONLY 25MM	Yes	DCV	DN25 (1")	1200 kPa	82°C	R1 X R1	COPPER ALLOY	29 Aug 2025
1-975XL3LFTBT	975XL3	ZURN WILKINS	1-975XL3LFTBT WILKINS BACKFLOW RPZ DEVICE ONLY 25MM	Yes	RPZD	DN25 (1")	1200 kPa	82°C	R1 X R1	COPPER ALLOY	29 Aug 2025
2-950XL3LFTBT	950XL3	ZURN WILKINS	2-950XL3LFTBT WILKINS BACKFLOW DCV DEVICE ONLY 50MM	Yes	DCV	DN50 (2")	1200 kPa	82°C	R2 X R2	COPPER ALLOY	29 Aug 2025
2-975XL3LFTBT	975XL3	ZURN WILKINS	2-975XL3LFTBT WILKINS BACKFLOW RPZ DEVICE ONLY 50MM	Yes	RPZD	DN50 (2")	1200 kPa	82°C	R2 X R2	COPPER ALLOY	29 Aug 2025
34-950XL3LFTBT	950XL3	ZURN WILKINS	34-950XL3LFTBT WILKINS BACKFLOW DCV DEVICE ONLY 20MM	Yes	DCV	DN20 (3/4")	1200 kPa	82°C	R3/4 X R3/4	COPPER ALLOY	29 Aug 2025
34-975XL3LFTBT	975XL3	ZURN WILKINS	34-975XL3LFTBT WILKINS BACKFLOW RPZ DEVICE ONLY 20MM	Yes	RPZD	DN20 (3/4")	1200 kPa	82°C	R3/4 X R3/4	COPPER ALLOY	29 Aug 2025

End of Record

Certificate No: WMKA1379 Issued Date: 8 October 2026

This schedule supersedes all previously issued schedules

*** For details of manufacture, refer to the licensee**

The WATERMARK is a registered certification trademark of Australian Building Codes Board ABN 74 599 608 295 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("INTERTEK SAI Global") Level 7 Suite 7.01, 45 Clarence Street, Sydney N SW 2000 Australia and subject to the INTERTEK SAI Global Terms and Conditions for Certification. In the issuance of this certificate, INTERTEK SAI Global assumes no liability to any party other than to the Client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with INTERTEK SAI Global requirements for systems certification. This certificate may only be reproduced in its entirety and remains the property of INTERTEK SAI Global, to whom it must be returned upon request. Refer to https://register.saiglobal.com/ for the list of product models.